

# Texas Commission on Environmental Quality

## Public Notification Form for Wastewater Discharges

### Information about the Discharge

An unauthorized discharge or spill of wastewater has occurred from:

Wastewater Treatment Facility:   X   Collection System:           

Facility Name: City of Leonard

Person to contact for information: Terry McCalpin

Location of spill(s): *CR 5070, Leonard*

Estimated date and time of spill(s): September 21, 2018 @ 10:00 P.M.

Estimated volume of spill(s)(number of gallons): 3 Million Gallons

Type of Spill (domestic, industrial, other): Domestic

Description of the area potentially affected, including down gradient and lateral distance from spill(s) site: Arnold Creek, South, Approx. One mile.

Suspected cause of spill(s): 12+ Inches Rain in 72 hr period and I&I.

### List of actions taken including but, not limited to:

Notification of:

Appropriate local government officials:   X   TCEQ Regional Office:   X  

Containment of spill: Not Applicable

Increased monitoring of water supply systems: Not Applicable

Initiation or completion of cleanup activities: September 24, 2018

If the public comes into contact with waste material, soil, or water potentially affected by the spill, they should bathe and wash clothes thoroughly as soon as possible